

# Design, Modelling and Performance Analysis of a Residential Grid-Tied Solar Photovoltaic System with Deferrable Load

**Presented: Waseem Ijaz (M.Eng Electrical)**

**Student ID: 202294973**

**Memorial University Of Newfoundland**

**Supervisor: Dr. M Tariq Iqbal**

**Date: 24<sup>th</sup> March 2025**


# Outline of Presentation

- Introduction
- Literature Review
- Research Objective
- Design and Result analysis of the PV System.
- Dynamic Modelling of the Solar System
- Design and Result analysis of the Solar System with Deferable Load
- Conclusion & Future Work

# Introduction

- Ever growing demand of Electricity in Pakistan due to increase in population and growing Economy.
- Heavy reliance on imported fossil fuels that cost government trade deficit.
- Solar and other form of renewable energy are environment friendly because they produce no GHG.
- Power outages due to short-fall of the national grid supply.
- Pakistan is geographically located in a region with abundant Solar Irradiation ranging between 1,600 to 2,200 kWh/m<sup>2</sup>/yr. Average Lahore receives around 1806 kWh/m<sup>2</sup>.
- This study aim to design, analyse grid-tied Hybrid system.

# Introduction



Pakistan Irradiance Map

# Introduction


## Types of Grid Connected Solar Systems.

### Grid-tied Solar System:

These systems are connected directly with grid without battery back-up.

Components of PV System:

- Solar Panels.
- Inverter
- Load.




# Introduction

## Grid-tied Hybrid Solar System:

Hybrid Solar system is connected with Grid and also provide load back-up.

Components of PV System.

- PV Panels.
- Batteries.
- Inverter.
- Load.



# Literature Review

| Paper Reviewed   | Deduction  |
|--|--|
| S. U. Rehman, S. Rehman, M. Shoaib, and I. A. Siddiqui                   | In this paper simulation using HOMER is carried-out to study the impact of different factors that can effect the efficiency of PV system |
| S. Akhtar, M. K. Hashmi, I. Ahmad, and R. Raza                           | Studying the effect of Concentrated solar energy for production of power in pakistan.  |
| S. Wilkinson, M. John, and G. M. Morrison                                | Studied the Multi-level perspective of Roof top PV panels in Australia   |
| MP Bakht, Z. Salam, M. Gul   | Wind, Solar & Generator based hybrid system that is used in Quetta Pakistan.   |
| H. Ahmad and F. Jamil  | Impact of producing expensive electricity from fossil fuels on economy and power outages.  |
| N. Jamal and O. Hohmeyer   | Increasing electricity demand and future of renewable energy in Pakistan.  |
| M. Irfan, Z.-Y. Zhao, M. Ahmad, and M. C. Mukeshimana                    | Economic impact of transformation from traditional fossil fuels to solar energy.   |
| S. Batool  | Effective Grid Management and Net metering   |
| M. Shahid, R. A. Butt, and A. Khawaja                                    | Design of Grid-tied Solar system for a house in Karachi, Pakistan.   |
| WA Haider, MA Aqeeq, MY Ayoub  | Economic feasibility study of Solar systems at multiple locations in Pakistan  |
| A. H. Tiwana   | Studying multiple factors that effect the efficiency of PV panels efficiency.  |
| A. H. Chohan, Z. A. Memon, A. I. Che-Ani, M. S. Arar, and J. Awad        | Design and feasibility study of multiple Grid-tied Solar system homes in UAE.  |
| M. U. Tahir, K. Siraj, S. F. Ali Shah, and N. Arshad                     | Case study of link between smart load management and solar energy production.  |
| W. ur Rehman, I. A. Sajjad, T. N. Malik, L. Martirano, and M. Manganelli | Feasibility study of grid tied Building Integrated PV system.  |
| G. E. Halkos and A. S. Tsirivis  | This research study link between growing economy and how it directly Carbon Emission.  |

# Research Objectives

**Develop and evaluate a grid-connected solar system for a residential setting in Lahore, aimed at addressing power shortage and enhancing grid efficiency.**

- To evaluate the economic benefit of installing an on-grid solar PV system using modelling tools such as SAM and HOMER Pro.
- To develop a computational model of a grid- connected PV System using MATLAB/Simulink and analyze its power generation dynamics, Inverter efficiency and grid interaction.
- To design a grid-tied solar system with deferrable air-conditioning loads, incorporating recent regulatory changes by NEPRA and assessing their impact on system performance and Return On Investment (ROI).



# Design & Analysis of PV System.

# Design and Analysis


## Site Location

- Site Coordinates are  $31^{\circ}27'49.0''$ N latitude and  $74^{\circ}28'25.7''$ E longitude
- House is in DHA Raya, Lahore.
- Plenty of space on the roof.
- House is occupied by 6 family member.




# Design and Analysis

## Electrical Energy Consumption



# Design and Analysis

## System Layout



# Design and Analysis

## Electrical Specification of Solar Panels

| Specification                             | Value                                   |
|---|---|
| Nominal Max. Power (P <sub>max</sub> )    | 340 W                                   |
| Opt. Operating Voltage (V <sub>mp</sub> ) | 37.9 V                                  |
| Opt. Operating Current (I <sub>mp</sub> ) | 8.97 A                                  |
| Open Circuit Voltage (V <sub>oc</sub> )   | 46.2 V                                  |
| Short Circuit Current (I <sub>sc</sub> )  | 9.48 A                                  |
| Module Efficiency                         | 17.49 %                                 |
| Operating Temperature                     | -40°C ~ +85°C                           |
| Max. System Voltage                       | 1500 V (IEC) or 1500 V (UL)             |
| Module Fire Performance                   | TYPE 1 (UL 1703) or CLASS C (IEC 61730) |
| Max. Series Fuse Rating                   | 15 A                                    |
| Application Classification                | Class A                                 |
| Power Tolerance                           | 0 ~ +5 W                                |

# Design and Analysis

## Specification of Inverter

| Type                        | Rating             |
|-----------------------------|--------------------|
| Maximum Output Power        | 8.2 kW             |
| Efficiency                  | 98%                |
| Input Voltage Range         | 80 V - 1000 V      |
| MPPT Voltage Range          | 270 V - 800 V      |
| Maximum Input Current       | 33 A               |
| Number of MPP Trackers      | 2                  |
| Nominal Input Voltage       | 710 V              |
| AC Nominal Output           | 8200 W             |
| Maximum PV Generator Power  | 12.3 kW            |
| Maximum Output Power        | 8200 VA            |
| AC Voltage Range            | 180 V - 270 V      |
| Frequency Range             | 45 - 65 Hz         |
| Total Harmonic Distortion   | <3%                |
| Protection Rating           | IP65               |
| Operating Temperature Range | -40°C to 55°C      |
| Dimensions                  | 645 x 431 x 204 mm |
| Weight                      | 21.5 kg            |

# Design and Analysis

## Specification of PV System

| Component                 | Specification                    |
|---------------------------|----------------------------------|
| Number of Panels          | 22 (2 strings of 11 panels each) |
| Rated Power per Panel     | 340 W                            |
| Total Solar Power Output  | 7,480 W (7.48 kW)                |
| Inverter                  | Fronius Primo 8.2                |
| Maximum Output Power      | 8.2 kW                           |
| Number of MPPT Inputs     | 2                                |
| Battery Model             | BAE Secura PVS 12 V 3 PVS 210    |
| Number of Batteries       | 4 (connected in parallel)        |
| Total Battery Voltage     | 48 V                             |
| Battery Capacity per Unit | 211 Ah                           |
| Total Battery Capacity    | 10.13 kWh                        |

# Design and Analysis


## System Performance Analysis

- **System Advisor Model (SAM)**
  - It is software developed by National Renewable Energy Laboratory (NREL).
  - Goal of software is to encourage the examination and financial analysis of renewable system.
  - Modeling of PV system and batteries storage can be done on software.
- **HOMER Pro**
  - HOMER Pro is all-round tool to design hybrid system.
  - Assist in finding cost-effective energy solution.
  - Utilize online solar irradiance and temperature to simulate system performance.
  - Software provide optimized solution of combination of different energy sources.




# Design and Analysis

## System Advisor Model (SAM)



Curve of Solar Panel simulated in SAM.




Inverter efficiency with respect to output voltage.

# Design and Analysis

## System Advisor Model (SAM)

- Electricity price was selected based on Peak and Off-peak rates.
- Electricity off-peak rate of 0.18/kWh.
- Electricity peak rate of 0.22/kWh.



|     | 12am | 1am | 2am | 3am | 4am | 5am | 6am | 7am | 8am | 9am | 10am | 11am | 12pm | 1pm | 2pm | 3pm | 4pm | 5pm | 6pm | 7pm | 8pm | 9pm | 10pm | 11pm |
|-----|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|------|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|------|
| Jan | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2   | 1    | 1    |
| Feb | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2   | 1    | 1    |
| Mar | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2   | 1    | 1    |
| Apr | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2    | 1    |
| May | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2    | 1    |
| Jun | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 2   | 2   | 2   | 2   | 2   | 2   | 1   | 1   | 1   | 1    | 1    |
| Jul | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 2    | 2   | 2   | 2   | 2   | 2   | 1   | 1   | 1   | 1   | 1    | 1    |
| Aug | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 2    | 2   | 2   | 2   | 2   | 2   | 1   | 1   | 1   | 1   | 1    | 1    |
| Sep | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2    | 1    |
| Oct | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2    | 1    |
| Nov | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2    | 1    |
| Dec | 1    | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1    | 1    | 1   | 1   | 1   | 1   | 2   | 2   | 2   | 2   | 2   | 1    | 1    |



# Design and Analysis

## HOMER Pro


- Irradiance and Temperature of the selected site by HOMER Pro.



# Design and Analysis

## HOMER Pro



- System Block Diagram



# Design and Analysis

## HOMER Pro

- Grid Tariffs & Schedule Outages




# Design and Analysis

## Results- SAM

| Metric                                   | Value        |
|--|--------------|
| Annual AC energy in Year 1               | 10,026 kWh   |
| DC capacity factor in Year 1             | 15.30%       |
| Energy yield in Year 1                   | 1,339 kWh/kW |
| Performance ratio in Year 1              | 0.69         |
| LCOE Levelized cost of energy nominal    | 6.22 ¢/kWh   |
| LCOE Levelized cost of energy real       | 2.95 ¢/kWh   |
| Electricity bill without system (year 1) | \$1,638      |
| Electricity bill with system (year 1)    | \$370        |
| Net savings with system (year 1)         | \$1,269      |
| Net present value                        | \$56,825     |
| Simple payback period                    | 2.7 years    |
| Discounted payback period                | 3.1 years    |
| Net capital cost                         | \$5,989      |
| Equity                                   | \$5,989      |

# Design and Analysis

## Results- SAM Monthly Load Profile.





- Demand of Electricity (Blue).
- PV Electricity production (Orange).
- Power From Grid (Brown).

# Design and Analysis

## Results- SAM

### PV Energy production VS Load.







# Design and Analysis

## Results- SAM Energy Flow

| Month | DC energy | AC energy | Load   | Electricity to/from grid |
|-------|-----------|-----------|--------|--------------------------|
| Jan   | 708.674   | 674.497   | 1293   | -618.503                 |
| Feb   | 702.061   | 668.041   | 589    | 79.0414                  |
| Mar   | 1067.86   | 1019.53   | 299.5  | 720.027                  |
| Apr   | 1013.28   | 965.1     | 646.3  | 318.8                    |
| May   | 1074.28   | 1023.35   | 714.1  | 309.246                  |
| Jun   | 944.115   | 898.251   | 612.75 | 285.501                  |
| Jul   | 789.571   | 748.419   | 1033.2 | -284.781                 |
| Aug   | 823.888   | 781.482   | 730.85 | 50.632                   |
| Sep   | 882.857   | 840.705   | 924.15 | -83.4447                 |
| Oct   | 863.086   | 822.264   | 619.15 | 203.114                  |
| Nov   | 898.49    | 857.817   | 470.6  | 387.217                  |
| Dec   | 761.551   | 726.436   | 521.05 | 205.386                  |

# Design and Analysis


## Results- SAM Projected Cashflow



# Design and Analysis

## Results- HOMER Pro System Structure & Cost Summary


- Total Capital Cost is \$ 5,340.
- Replacement Cost of the battery is \$ 10,819.
- Total cost of the system through out the lifetime \$ 71,485.
- Significant portion of cost comes from Solar Panels & Batteries.
- Batteries require replacement every four year.



| Component                          | Capital (\$) | Replacement (\$) | O&M (\$)    | Fuel (\$) | Salvage (\$) | Total (\$)  |  |
|------------------------------------|--------------|------------------|-------------|-----------|--------------|-------------|--|
| ▷ BAE SECURA SOLAR 12 V 3 PVS 210  | \$1,040.00   | \$10,819.59      | \$8,384.59  | \$0.00    | (\$1,969.09) | \$18,275.10 |  |
| ▷ CanadianSolar MaxPower CS6U-340M | \$2,100.00   | \$0.00           | \$31,442.23 | \$0.00    | \$0.00       | \$33,542.23 |  |
| ▷ Fronius Primo 8.2-1              | \$2,200.00   | \$0.00           | \$6,288.45  | \$0.00    | \$0.00       | \$8,488.45  |  |
| ▷ Grid                             | \$0.00       | \$0.00           | \$11,179.73 | \$0.00    | \$0.00       | \$11,179.73 |  |
| System                             | \$5,340.00   | \$10,819.59      | \$57,295.00 | \$0.00    | (\$1,969.09) | \$71,485.50 |  |

# Design and Analysis

## Results- HOMER Pro Cash Flow



# Design and Analysis


## Results- HOMER Pro Electrical Production

| Production                       | kWh/yr | %    |
|----------------------------------|--------|------|
| CanadianSolar MaxPower CS6U-340M | 10,540 | 67.1 |
| Grid Purchases                   | 5,176  | 32.9 |
| Total                            | 15,716 | 100  |

| Consumption     | kWh/yr | %    |
|-----------------|--------|------|
| AC Primary Load | 8,453  | 61.2 |
| DC Primary Load | 0      | 0    |
| Deferrable Load | 0      | 0    |
| Grid Sales      | 5,365  | 38.8 |
| Total           | 13,819 | 100  |

| Quantity            | kWh/yr | %    |
|---------------------|--------|------|
| Excess Electricity  | 1,252  | 7.97 |
| Unmet Electric Load | 0      | 0    |
| Capacity Shortage   | 0      | 0    |





| Quantity                | Value | Units |
|-------------------------|-------|-------|
| Renewable Fraction      | 62.5  | %     |
| Max. Renew. Penetration | 1,250 | %     |



# Design and Analysis


## Results- HOMER Pro

### PV Power Output, Power Grid Import , Export Graph & Battery SOC



# Design and Analysis

## Comparison



# Modelling & Simulation of Grid-Tied Solar System



# Modelling & Simulation

- **MATLAB/ SIMULINK**

- It provides versatile platform for system modelling.
- Ideal of Power systems. Including Solar Systems(PV panels, Grid, Batteries)

- **Focus of Work**

- Modelling and simulation of Grid-tied Solar Inverter, with real-time Dynamics.


# Modelling & Simulation

- **Key Components of Hybrid Power System.**
  - Photovoltaic Panels.
  - Maximum Power Point Tracking (MPPT).
  - Buck Converter.
  - Batteries with Charge Controller.
  - Boost Converter.
  - DC- AC Inverter.
  - Phase Lock Loop.
  - Load.

# Modelling & Simulation


- **MPPT Algorithm**

- To track the Maximum power point the algorithm used in modelling is P&O (Perturb and Observe) Algorithm.




# Modelling & Simulation

- Simulation Model



# Modelling & Simulation


- DC- AC Inverter (SPWM)



# Modelling & Simulation

- **Results**


- Dynamic response with changing Irradiance.



**Power from PV Setup**

# Modelling & Simulation

- Results
  - Battery Response with changing Irradiance.




Battery Parameters

# Design & Analysis of PV System With Deferable Load.



# Design and Analysis


## System Layout



# Design and Analysis

## Schematic of System

- **Components of System**
  - PV Panels.
  - Batteries.
  - Grid Connection.
  - Inverter
  - Electrical Load
  - Deferable Load




# Design and Analysis

## Deferable Load

During month of June, July & August Average Deferable load in our study is 25.8 kWh/day. Type of load on Deferable Load are

- Air-conditioner.
- Water Pump.
- Washing Machine.



| Month     | Average Load (kWh/d) |
|-----------|----------------------|
| January   | 0.800                |
| February  | 0.800                |
| March     | 0.800                |
| April     | 0.800                |
| May       | 0.800                |
| June      | 25.800               |
| July      | 25.800               |
| August    | 25.800               |
| September | 0.800                |
| October   | 0.800                |
| November  | 0.800                |
| December  | 0.800                |


**Annual Average (kWh/d): 7.05**

# Design and Analysis

## Grid Revised Rate

Grid Unit rate is same for Off-peak and Peak power consumption.

- Sell Back rate is changed from 0.08 \$/kWh to 0.039 \$/kWh.




|        |  |  | Price<br>\$/kWh | Sellback<br>\$/kWh |      |   |
|--------|--|--|-----------------|--------------------|------|---|
| Rate 1 |  |  | 0.1800          | 0.0390             | Edit | ✕ |
| Rate 2 |  |  | 0.2200          | 0.0390             | Edit | ✕ |

# Design and Analysis

## Results- Cost Summary


- Total Capital Cost is \$ 5,340.
- Replacement Cost of the battery is \$ 10,819.
- Total cost of the system through out the lifetime \$ 76,120.
- Cost of system has increased because of reduced buy back rate to grid.



| Component                          | Capital (\$) | Replacement (\$) | O&M (\$)    | Fuel (\$) | Salvage (\$) | Total (\$)  |  |
|------------------------------------|--------------|------------------|-------------|-----------|--------------|-------------|--|
| ▷ BAE SECURA SOLAR 12 V 3 PVS 210  | \$1,040.00   | \$10,819.59      | \$8,384.59  | \$0.00    | (\$1,969.09) | \$18,275.10 |  |
| ▷ CanadianSolar MaxPower CS6U-340M | \$2,100.00   | \$0.00           | \$31,442.23 | \$0.00    | \$0.00       | \$33,542.23 |  |
| ▷ Fronius Primo 8.2-1              | \$2,200.00   | \$0.00           | \$6,288.45  | \$0.00    | \$0.00       | \$8,488.45  |  |
| ▷ Grid                             | \$0.00       | \$0.00           | \$15,814.67 | \$0.00    | \$0.00       | \$15,814.67 |  |
| System                             | \$5,340.00   | \$10,819.59      | \$61,929.94 | \$0.00    | (\$1,969.09) | \$76,120.44 |  |

# Design and Analysis

## Results- Cash Flow



- System has Capital Cost of \$ 5,340.
- Batteries need to be replaced after every 4 Years.

# Design and Analysis

## Results- Electrical Production.


| Production                       | kWh/yr | % |
|----------------------------------|--------|---|
| CanadianSolar MaxPower CS6U-340M | 10,540 | 7 |
| Grid Purchases                   | 3,941  | 2 |
| Total                            | 14,480 | 1 |

| Consumption     | kWh/yr | %    |
|-----------------|--------|------|
| AC Primary Load | 5,840  | 45.4 |
| DC Primary Load | 0      | 0    |
| Deferrable Load | 2,591  | 20.1 |
| Grid Sales      | 4,444  | 34.5 |
| Total           | 12,875 | 100  |

| Quantity            | kWh/yr | %       |
|---------------------|--------|---------|
| Excess Electricity  | 1,104  | 7.63    |
| Unmet Electric Load | 0.359  | 0.00430 |
| Capacity Shortage   | 0.489  | 0.00580 |



| Quantity                | Value | Units |
|-------------------------|-------|-------|
| Renewable Fraction      | 69.4  | %     |
| Max. Renew. Penetration | 1,396 | %     |








# Design and Analysis

## Results- HOMER Pro

### PV Power Output, Power Grid Import , Export Graph & Battery SOC





# Design and Analysis

## Results- Conclusion

- Solar System has Peak performance during the summer months because of High Solar Irradiance.
- Using Deferrable load helped us to optimize and use maximum energy at the day-time when solar irradiance is high.
- With Reduced net-metering rates the ROI of the system is decreased to 23% from previous ROI of 29%.
- Levelized Cost of Energy is also increased from \$ 0.123/kWh to \$ 0.141/ kWh because of reduced grid feed rates.
- Using Deferrable Load increased the self-consumption of the household load.
- Renewable energy fraction increased to 69.4% from 62.5%.
- Maximum Renewable Penetration is increased from 1,250 % to 1,396 %.
- Total Renewable production divided by load increased from 76.3% to 81.9%.

# Conclusion & Future Work.

# Conclusion

## **Design & Analysis of Grid-tied Photovoltaic System**

- Designed the system calculating actual load of the house.
- Carried-out simulation of the system using two softwares SAM & HOMER Pro, validating the performance of the system.
- Net-metering option was selected to maximize the solar energy utilizing and increase system viability.

## **Dynamic Modeling of the System**

- Dynamic Performance of the hybrid System was evaluated using MATLAB/SIMULINK.
- Simulation showed us Stable Voltage, State of Charge & Battery Current with Varying irradiance.
- Reliable performance of the system in meeting real world energy needs.

## **Design & Analysis of Grid-tied Photovoltaic System**

- Decreased export rate to grid have negative impact on ROI and decreases the economic feasibility of the system.
- Deferrable load helps optimize the use of renewable energy.
- With Deferrable load no surplus energy was sold to grid in month of June, July & August and was self consumed in house.

# Future Work

## **Advance Load Management**

- Using AI/ Machine Learning to study Load pattern of energy consumption.
- Optimizing Deferrable Load scheduling accordingly.
- Intelligent control system that can prioritize between critical and non-critical Load.

## **Scaling to Diverse Location**

- Study system response under different geographical locations.
- Analyze system response under different Temperature & Solar irradiance condition.

## **Peer-to-Peer Energy Trade**

- Research to be carried-out to study peer-to-peer energy trading model.
- Decentralized Energy Distribution.
- It reduces reliance on centralized energy distribution.
- With decreasing export rates this will increase the economic viability of micro grids.

# List of Publications

- W. Ijaz and M. T. Iqbal, “Design and Analysis of an On-Grid Solar System House in Lahore Pakistan,” *Eur. J. Electr. Eng. Comput. Sci.*, vol. 8, no. 6, Art. no. 6, Nov. 2024, doi: 10.24018/ejece.2024.8.6.652.
- W. Ijaz and M. T. Iqbal, “Dynamic Modeling of on Grid-Connected Photovoltaic Setup in Pakistan using MATLAB,” *Eur. J. Electr. Eng. Comput. Sci.*, vol. 9, no. 2, Art. no. 2, Mar. 2025, doi: 10.24018/ejece.2025.9.2.681
- W. Ijaz and M. T. Iqbal, “Design and Analysis of A Grid-tied Solar System with Deferable Air-Conditioning Load For Lahore, Pakistan.” is reviewed and accepted by *Eur. J. Of Energy Research* and is under publication phase.

Thank you  
For your Attention!!

Any Questions ?